


SLP (UK) LTD

30-Arrowlite-polycarbonate

INTENSITY VALUES CANDELAS PER 1000 LUMENS

	0	15	30	45	60	75	90
0	288.24	288.24	288.24	288.24	288.24	288.24	288.24
5	286.41	292.68	279.41	291.89	282.04	288.31	282.78
10	287.92	282.64	280.80	275.37	278.10	275.66	277.23
15	268.31	267.16	279.12	279.70	280.10	272.47	276.58
20	266.65	269.82	260.56	261.62	260.19	257.16	265.31
25	253.72	245.76	246.07	255.16	254.51	245.07	242.52
30	231.11	231.56	238.36	231.93	229.38	232.98	233.09
35	220.62	217.82	222.81	221.82	214.79	219.44	213.31
40	205.45	197.04	197.01	196.92	200.48	196.01	200.01
45	185.28	182.09	178.24	179.53	184.16	183.66	175.33
50	158.56	164.88	158.54	162.72	160.51	161.39	156.48
55	141.07	140.54	136.25	140.92	134.72	136.66	134.49
60	116.22	115.70	120.55	115.90	116.27	113.90	118.72
65	97.46	94.10	94.41	97.82	96.16	93.45	93.19
70	73.27	69.74	69.49	72.33	71.72	70.03	71.60
75	49.91	47.65	49.13	48.21	49.02	46.31	46.73
80	27.87	28.57	28.18	28.60	27.26	26.87	25.83
85	8.98	9.33	9.23	9.47	8.91	8.53	8.49
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00



Spacing To Mounting Height Ratio

Nominal S/Hm.	1.25
Maximum S/Hm.	1.38
Maximum Transverse S/Hm.	-

Light Output Ratio's

Upward Light Output	ULOR	0%
Downward Light Output	DLOR	0.82%
Total	LOR	0.82%

Utilisation Factors for a Nominal S/Hm. of 1.5

Ceiling	Walls	Floor	Room Index								
			0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
70%	50%	20%	.44	.52	.58	.62	.68	.72	.74	.78	.80
	30%		.38	.47	.52	.57	.63	.67	.71	.75	.78
	10%		.34	.42	.48	.53	.59	.64	.67	.72	.75
50%	50%	20%	.43	.51	.56	.60	.65	.69	.72	.75	.77
	30%		.38	.46	.51	.56	.61	.66	.71	.75	.78
	10%		.34	.42	.47	.52	.58	.62	.66	.70	.73
30%	50%	20%	.42	.49	.54	.58	.63	.67	.69	.72	.74
	30%		.37	.45	.50	.54	.60	.64	.66	.70	.72
	10%		.34	.41	.47	.51	.57	.61	.64	.68	.71
0%	0%	0%	0.32	0.39	0.45	0.49	0.54	0.58	0.61	0.65	0.67
BZ CLASSIFICATION			5	4	4	4	4	4	4	4	4

All Photometry conducted in accordance to BS5225:Part 1:1975

Calculations conducted to CIBSE TM5 & TM10

Uncorrected Glare Indices available upon request